

Resolution No. 117

WHEREAS, General Condition G14 of the NPDES Permit (No. WA-002502-0) for the Skagit Nuclear Power Project provides that:

"Prior to construction, Permittee shall advise the Council of the design redundancy in the settling capacity of the storm runoff settling ponds with regard to the maximum 24-hour, 10-year rainfall expectancy (3.5 inches). The Council reserves the right to require increased pond capacity or to require such other action as it deems necessary," and

WHEREAS, the Puget Sound Power and Light Company has submitted a report entitled: "Evaluation of Storage Capacity Adequacy, Sediment Retention Facilities for the Skagit Nuclear Power Project," and

WHEREAS, said report has been reviewed and found sufficient for its purpose,

NOW THEREFORE BE IT RESOLVED by the Energy Facility Site Evaluation Council that the requirements of General Condition G14 of the NPDES Permit, No. WA-002502-0, have been satisfied.

Dated this 14th Day of March 1977.

WASHINGTON STATE ENERGY
FACILITY SITE EVALUATION COUNCIL

By Lawrence B. Bradley
Lawrence B. Bradley
Chairman

ATTEST:

By Roger Polzin
Roger Polzin
Executive Secretary

APPROVED AS TO FORM:

By Thomas F. Carr
Thomas F. Carr
Assistant Attorney General