

Resolution No. 118

WHEREAS by letter of March 7, 1977 WPPSS did request consultation pursuant to Paragraph III.F.2 and approval pursuant to Paragraph III.F.3 of the Site Certification Agreement for WPPSS Nuclear Projects Nos. 1 & 4; and

WHEREAS on March 29, 1977 WPPSS did consult with the Council pursuant to Paragraphs III.F.2 & III.G.2 of the Site Certification Agreement for WPPSS Nuclear Projects Nos. 1 & 4; and

WHEREAS such consultation covered Phases I & II of the intake and outfall construction leaving for later consultation the concluding Phase III of said construction;

NOW THEREFORE BE IT RESOLVED that the Energy Facility Site Evaluation Council hereby approves Phases I and II as described in the following documents: 1) Drawing No. 9779-F-100305, March 25, 1977 Revision; 2) Division 2, Sections 2B and 2C of Contract Specification 9779-255 Revision "A"; and 3) "Makeup Water Pump House Construction Summary," February 18, 1977 Revised March 25, 1977 as partial satisfaction of Paragraphs III.F.3 & III.G.3 of the Site Certification Agreement for WPPSS Nuclear Projects Nos. 1 & 4 provided that:

1. Trench dewatering flows will be filtered through unconsolidated soils and the protective riprap of the north wing of the cofferdam and such soils and riprap will be later disposed of onshore, and

2. Further discussions on Phase III will precede final approval pursuant to Certification Agreement Paragraphs III.F.3 & III.G.3.

Dated this 11th day of April 1977.

WASHINGTON STATE ENERGY FACILITY
SITE EVALUATION COUNCIL

BY Lawrence B. Bradley
Lawrence B. Bradley
Chairman

ATTEST:

By William L. Fitch
William L. Fitch
Council Coordinator

APPROVED AS TO FORM:

By Thomas F. Carr
Thomas F. Carr
Assistant Attorney General