

Resolution No. 146

WHEREAS, The Energy Facility Site Evaluation Council did on February 27, 1978 by Resolution No. 134 approve the Washington Public Power Supply System's construction of the river intake and discharge systems for WPPSS Nuclear Projects Nos. 1 and 4 and did specify that excavation activities within stream channels shall be accomplished within the period August 1 to September 30; and

WHEREAS, The Washington Public Power Supply System did request on September 8, 1978 by its letter subject: WPPSS Nuclear Projects Nos. 1 and 4 Request for Extension in the River Construction Period for Intake Outfall System, that because of problems encountered by the contractor and the high river flows which have delayed completion of the project, the construction period be extended to 2400 hours on October 15, 1978; and

WHEREAS, The Energy Facility Site Evaluation Council did consider this matter at its regular meeting of September 11, 1978 and did approve the extension;

NOW, THEREFORE, BE IT RESOLVED That paragraphs B, C, D and D.2 of Resolution No. 134 are herewith amended as follows:


- B. Excavation activities within stream channels shall be accomplished within the period August 1 to ~~September-30~~ October 15.
- C. The city of Richland and the Hanford Operations Office shall be notified prior to the commencement of in-stream excavation activity, and shall be notified of any extension of such in-stream excavation activity.
- D. The water quality criteria set forth in WAC 173.201.030 (2) (c) (vi) as for turbidity is hereby modified for the period beginning 0100 hours, August 1, 1978, and terminating 2400 hours, ~~September-30~~ October 15, 1978 in accordance with the following conditions:
  - 2. Turbidity and total suspended solids measurements shall be taken daily between August 1 and ~~September 30~~ October 15, 1978 during excavation or backfilling

work at the following locations: a point in close proximity to, and upstream of the excavation area; approximately 300 feet below the excavation area, and approximately one (1) mile below the excavation area.

Dated this 11th day of September 1978.

WASHINGTON STATE ENERGY FACILITY  
SITE EVALUATION COUNCIL

BY

  
Nicholas D. Lewis  
Chairman


ATTEST:

BY

  
William L. Fitch  
Executive Secretary

APPROVED AS TO FORM:

BY

  
Thomas F. Carr  
Assistant Attorney General