

RESOLUTION NO.173

*Superseded by
Resolution #203
dated 2/22/82*

WHEREAS, By letter of December 5, 1979, the Washington Public Power Supply System did request in accordance with Section III.D.6 of the Site Certification Agreement for WPSS Nuclear Projects 3 and 5, for a turbidity waiver in relation to the proposed installation of a blowdown diffuser in the Chehalis River; and,

WHEREAS, The Council recognizes that short term increases in turbidity may result from installation of the blowdown diffuser;

NOW, THEREFORE, BE IT RESOLVED By the Energy Facility Site Evaluation Council that it grants a temporary waiver of the water quality standards subject to the following conditions:

1. Construction will be in accordance with the attached drawing.
2. Detailed construction plans will be submitted to the Council in accordance with Sections III.G.2 and III.G.3 of the Site Certification Agreement.
3. Construction activity in the Chehalis River main stem must be confined to the period June 1 to September 15.
4. No discharge of visible oil and grease will be permitted to reach any receiving water.
5. The water quality criteria set forth in WAC 173.201.030 (2)(C) (vi) as for turbidity is hereby modified for the period beginning 0100 hours on June 1, 1981 and terminating 2400 hours, September 15, 1981 in accordance with the following condition:

*done
2/22/82*

Sampling of the Chehalis River upstream and downstream of the construction area will be done daily during construction activity. Sampling results will be reported to the Council monthly. Analyses will be for turbidity and settleable solids.

Dated this 28th day of April, 1980.

WASHINGTON STATE ENERGY FACILITY
SITE EVALUATION COUNCIL

By Nicholas D. Lewis
Nicholas D. Lewis
Chairman

ATTEST: