

Resolution No. 206

*Closed out by  
Resol. #217 - 5/23/83*

WHEREAS, by letter dated July 9, 1982, the Washington Public Power Supply System did, in accordance with Sections III.D.6 and III.F.5(b) of the Site Certification Agreement for Supply System Nuclear Projects 3 and 5, request a turbidity waiver for work associated with repairs to the intake well field bank protection; and,

WHEREAS, the Supply System described the proposed repairs in its letter of July 9, 1982 and its attachment, and

WHEREAS, the Council recognizes that short-term increases in turbidity may occur during the course of this work.

NOW, THEREFORE, BE IT RESOLVED, by the Energy Facility Site Evaluation Council that it grants a temporary waiver of the water quality standards subject to the following conditions:

1. The removal of damaged gabions shall be accomplished as described in the attached letter to the Army Corps of Engineers.
2. Detailed construction plans shall be submitted to the Council in accordance with Section III.F.5(b) of the Site Certification Agreement.
3. No discharge of visible oil or grease shall be permitted to reach any receiving water.
4. Construction activity in the Chehalis River must be confined to the period June 1 to September 15 unless otherwise specifically approved by the Council.
5. Fill or borrow areas shall be erosion stabilized as soon as possible and in a manner equivalent to adjacent undisturbed areas.
6. Fill areas shall be contoured to avoid the creation of fish traps.
7. The water quality criteria set forth in WAC 173.201.030(2)(c)(vi) as for turbidity is hereby modified for the period beginning 0100 hours July 13, 1982 and terminating 2400 hours September 15, 1982, subject to the following conditions:

Sampling of the Chehalis River upstream and downstream of the construction area shall be done daily during construction activity. The samples shall be analyzed for turbidity and settleable solids and the results reported to the Council monthly.


8. The State of Washington, acting by and through the Council,

the construction of WNP-3/5 so long as done in accordance with this order or subsequent orders and the Site Certification Agreement executed on October 27, 1976, will comply with applicable State law and the limitations identified herein.

Dated this 12th day of July, 1982.


WASHINGTON STATE ENERGY FACILITY  
SITE EVALUATION COUNCIL

BY

  
Nicholas D. Lewis  
Chairman

ATTEST:

BY

  
William L. Fitch  
Executive Secretary