

RESOLUTION No. 213

WHEREAS, the Washington Public Power Supply System, by letter dated October 11, 1982, did request that the WNP-3/5 Oil Spill Prevention and Countermeasure Plan be supplemented to allow for an increase in the amount of mineral oil necessary to store the Unit 5 transformers in the West Cooley Laydown Area; and


WHEREAS, condition 3 of Resolution No. 197 requires the Supply System to supplement the oil spill plan when they desire to store materials in substantially greater quantities than those found in the approved plan; and

WHEREAS, the Council has reviewed the request and finds that generally adequate provisions have been made to accommodate the storage of such materials.

NOW, THEREFORE, BE IT RESOLVED, that the Energy Facility Site Evaluation Council hereby approves such increase in the inventory of mineral oil and the storage of transformers, provided that all transformer drain valves be made as tamper proof as feasible and that the commitment to same be executed and reported expeditiously.

Dated this 8th day of November 1982.

WASHINGTON STATE ENERGY FACILITY
SITE EVALUATION COUNCIL

By 

Nicholas D. Lewis
Chairman

ATTEST:

By 

William L. Fitch
Executive Secretary