

RESOLUTION NO. 236

WHEREAS, The Washington Public Power Supply System Nuclear Project No. 3 has been required to maintain a storm water runoff chemical treatment facility located at the equalization and settling ponds in order to meet the conditions of the NPDES Permit; and

WHEREAS, During the rainfall event in November 1986, NPDES permit conditions were met without operating the chemical treatment facility; and

WHEREAS, The Council has reviewed site conditions and concurs with the Supply System that NPDES permit conditions can be met without treating the runoff; and

WHEREAS, By letter dated November 13, 1986, the Supply System requested approval to change the status of the central site chemical treatment system from operational standby to "lay-up," and the Council agrees that this status change is appropriate,

NOW, THEREFORE, BE IT RESOLVED, By the Energy Facility Site Evaluation Council that the Supply System may "lay-up" the central site chemical treatment facility as described in their letter of November 13, 1986, provided that a one week supply of flocculent is maintained on-site and that treatment could resume within 72 hours should site conditions warrant treatment to meet NPDES permit conditions.

Dated this 8th day of December 1986

Washington State Energy Facility
Site Evaluation Council

By 
Curtis Eschels
Chairman

ATTEST:

By 
William L. Fitch
Executive Secretary