

**Response to Comment in Letter CO3 from
C. David Sellars, Huntingdon Duty Free Shop, Inc.**

*Note: The response listed below is numbered to correspond to the number shown
in the right-hand margin of the preceding comment letter.*

1. The threat of flooding in the Sumas valley is recognized. The floods that have occurred as well as the conditions leading to the flooding have been taken into consideration in the flood modeling that has been done for the plant site area. These factors also will be considered in the unsteady state flood modeling that the Applicant would conduct for the plant site. Please note that issues pertaining to the need to dredge the Nooksack River or flooding of the Fraser River are not addressed in this SEIS and are beyond EFSEC's jurisdiction.