

[REVISED]

Table 2.3-3

Emission Summary Table

(REVISED)

	Maximum ¹ Permitted Cogeneration Emissions Tons/yr		Expected ² Cogeneration Emissions Tons/yr	Refinery Emission Reductions Tons/yr	Net ³ Change Tons/yr
NOx	233		181	-499	-318
CO	158		81	-54	27
VOC	42		28	-3	25
PM10/2.5	262		94	-10	84
SO2	51		50	-7	43
Total	746		434	-573	-140

¹ Maximum Permitted Emissions reflect the permit limits proposed in the PSD application. and include the maximum permitted emissions for the gas turbines, cooling tower, emergency generator, and emergency fire water pump.

² The expected emissions are based upon the assumptions explained in section 3.2.3.2 of the Application for Site Certification.

³ Totals may not equal sum of individual components due to rounding.