

## **2.5 WATER SUPPLY SYSTEM**

*WAC 463-42-165 Proposal – Water supply system. The applicant shall describe the location and type of water intakes and associated facilities.*

As operation of the Project does not require water for cooling as does a thermal power plant, water needs will be minimal and primarily for bathroom and kitchen use at the O&M facility which is anticipated to be less than 1,000 gallons daily. Water will be obtained from a domestic well that will be installed by a licensed installer. The Applicant will seek and obtain approval for the new well from Kittitas County Environmental Health Department and Washington Department of Ecology.

There will be no discharges to groundwater from Project operations. Wastewater from the O&M facility will be discharged to a domestic septic tank installed pursuant to the requirements of Kittitas County Environmental Health Department.