BP Cherry Point Cogeneration



SO2 maximum 24-hour concentration (ug/m3)
No refinery emission reductions
Maximum over 5-year period
ISC-Prime model

US SIL	25
US AAQS (WA)	1.300
Canadian Objective (most stringent)	375