BP Cherry Point Cogeneration



CO maximum 1-hour concentration (ug/m3)
No refinery emission reductions
Maximum over 5-year period
ISC-Prime model

US SIL	2,000
US AAQS	40,000
Canadian Objective (most stringent)	14,300