BP Cherry Point Cogeneration



PM10 maximum annual concentration (ug/m3)
With all emission reductions and secondary particulate
Maximum over 1-year period
CalPuff model

US SIL	1
US AAQS	50
Canadian Objective (most stringent)	30