

AMENDMENT NO. 1 TO THE  
SITE CERTIFICATION AGREEMENT FOR HANFORD NO. 2  
BETWEEN  
THE STATE OF WASHINGTON  
AND  
THE WASHINGTON PUBLIC POWER SUPPLY SYSTEM

This amendment to the Certification Agreement was made and entered into pursuant to Chapter 80.50 of the Revised Code of Washington by and between the State of Washington, acting by and through the Governor of the State of Washington, and the Washington Public Power Supply System, a municipal corporation and a joint operating agency of the State of Washington organized in January 1957 pursuant to Chapter 43.52 of the Revised Code of Washington.

It includes changes to the terms for the construction of the intake system, commencement of the meteorological and environmental surveillance program, scope of the agreement limitations, dimensions of the mixing zone, and specifications for management of waste water discharges. The entire section containing water discharge limitations has been superseded and replaced by the issuance of a National Pollutant Discharge Elimination System Waste Discharge Permit in compliance with the provisions of Chapter 90.48 RCW as amended and the Federal Water Pollution Control Act Amendment of 1972, Public Law 92-500.

This amendment, when duly authenticated, becomes a part of the Certification Agreement and will be filed in front of the Agreement. The following is changed:

A. Section II.C.1. is amended to read as follows:

This Certification Agreement, together with those commitments made by the applicant expressed in its application, as amended, except as to commitments made for the design for the intake and discharge systems, constitute the whole and complete agreement between the parties and supersedes any other negotiations, representations, or agreements, either written or oral.

B. Section III.G.4.(a) is deleted.

C. Section III.G.4.(b) is replaced with the following:

The Supply System shall schedule the construction of the intake structure in the portion of the river bed during the period after July 31 and before October 15. Any work at other times directly in the stream bed of the Columbia River shall require approval of the Council.

D. Section III.H. Add the following as Paragraph 6:

The outfall shall include features as required to achieve dilution within the limits prescribed in General Condition 4 of the attached NPDES Permit.

- E. Section IV.B. is deleted and replaced with the Hanford No. 2 National Pollutant Discharge Elimination System Waste Discharge Permit hereby appended as Attachment II to the Certification Agreement.
- F. Section V.B.1. The last sentence of this paragraph is deleted and replaced with the following:

"The Supply System agrees to begin the meteorological and environmental surveillance program no later than two years prior to fuel loading; provided that fish impingement monitoring shall begin no later than intake pump startup."

Dated at Olympia, Washington, this 25<sup>th</sup> day of September 1975.


FOR THE STATE OF WASHINGTON

  
Daniel J. Evans, Governor

FOR THE WASHINGTON PUBLIC  
POWER SUPPLY SYSTEM

  
J. J. Stein, Managing Director

Approved as to form this 25<sup>th</sup> day of September 1975

  
Darrel L. Peebles  
Assistant Attorney General

SITE CERTIFICATION AGREEMENT  
BETWEEN  
THE STATE OF WASHINGTON  
AND  
THE WASHINGTON PUBLIC POWER SUPPLY SYSTEM

FOR  
HANFORD NO. 2  
Nuclear Electric Generating Facility  
Benton County, Washington

May 17, 1972