

Washington State Patrol
General Administration Building
PO Box 42600 Olympia WA 98504-2600 (360) 596-3900

Business Name	EFSEC Grays Harbor Energy	Provider Number	
	401 Keys RD,	Approval Status	Approved
City, State, Zip	Elma, WA	Facility Type	Contracted Inspections
On 1/19/2 018 the Office of the State Fire Marshal conducted an inspection at your facility.			
「 17 18 Code Reference		Statement of Deficiencies	
1 Inspection, testing and maintenance.			
smoke exhaust syst maintained in an opo replaced or repaired	,		
2 Smoke detector sensitivity.			
after installation and second calibration to detector has remain range (or 4-percent marked), the length permitted to be exte the frequency is extraordinated alarms and be maintained. In zo	sitivity shall be checked within one year levery alternate year thereafter. After the est, where sensitivity tests indicate that the ed within its listed and marked sensitivity obscuration light grey smoke, if not of time between calibration tests shall be ended to a maximum of five years. Where ended, records of detector-caused d subsequent trends of these alarms shall ones or areas where nuisance alarms show he previous year, calibration tests shall be		
3 Power test.			
emergency lighting The power test shal	d emergency lighting, a power test of the equipment shall be completed annually. I operate the emergency lighting for a utes and shall remain sufficiently illuminated ne test.		

Business Name EFSEC Grays Harbor Energy

401 Keys RD,

City, State, Zip Elma, WA **Provider Number**

Approval Status Approved

Facility Type

Contracted Inspections

Reinspection Date:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12-025.

Owner op Owner's Representative

Signature

Deputy State Fire Marshal Lance Talley